

Architect:  
TCF Architecture PLLC  
902 North 2nd Street  
Tacoma, Washington 98403

**PROJECT DOCUMENTS**  
for  
**CITY HALL PHASE 1**  
**EXTERIOR ENVELOPE REPLACEMENT**

City of Fife  
Fife, Washington  
TCF Architecture Project Number 2012-008

This addendum modifies or interprets (by addition, deletion, clarification or correction) and takes precedence over previously issued Bidding Documents for Project Manual dated 21 October 2016 and as such is part of the Contract Documents for this project.

The General Contractor is responsible for coordinating the revised or added work of related trades when a change is made in the work of any trade in the addendum.

All Subcontractors shall review each item of the addendum and provide the coordination, accessories, and other work necessary for the complete and proper inclusion of addendum items.

The General Contractor and Subcontractor shall include in their bids all labor, materials and equipment and overhead necessary for the complete and proper inclusion of all addendum items.

**NOTE: THE CONTRACTOR SHALL ACKNOWLEDGE RECEIPT OF ALL ADDENDA ON THE FORM OF PROPOSAL**

Attachments to Addendum 1

- Architectural Addendum 2 1 page
- Total** **2 pages** (including this cover sheet)

**INDEX TO ARCHITECTURAL ADDENDUM 2:**

- Item I: Addendum 1
- Item II: Project Manual - Specifications
- Item III: Drawings

**ITEM I: ADDENDUM 1 COVERSHEET**

1. **Revise the first paragraph as follows:**

This addendum modifies or interprets (by addition, deletion, clarification or correction) and takes precedence over previously issued Bidding Documents for Project Manual dated ~~29 August 2014~~ **October 21, 2016** and as such is part of the Contract Documents for this project.

**ITEM II: PROJECT MANUAL - SPECIFICATIONS**

1. **Revise** Section 088400 – PLASTIC GLAZING
  - A. **Replace** 2.4 A. 4. with Color: Ice.
  - B. **Remove** 2.4 A. 4a.

**ITEM III: DRAWINGS**

1. **Sheet A2.00 Reflected Ceiling Plan**
  - A. **Replace** note “Remove & reinstall existing corrugated metal ceiling panels” with **“Remove existing ceiling panels back to first joint and install new ceiling panels per specs.”**
  - B. **Replace** note “Fill opening @ removed projection screen w/ painted MDF panel” with **“Carefully remove existing projection screen and salvage for owner”**
2. **Sheet A60.01 Details 1A, 1, and 1B**
  - A. **Add** note **“At all polycarbonate panels, provide matching polycarbonate edge profile with exposed face screwed fasteners provided by manufacturer spaced @ 18” O.C.”**
  - B. **Add** note **“At all lighted “slots” provide white prefinished 26 gauge sheet metal panels to match size of “slot”. Face screw panels over building paper to wall at 24” O.C.”**

**END OF ARCHITECTURAL ADDENDUM NUMBER 2**